



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ
Dilovası OSB Mahallesi Fırat Caddesi No: 18
Dilovası, Kocaeli / TÜRKİYE
www.effectis.com

DECLARATION OF TEST RESULTS

No: ERA – 2200 – 0012

The related reaction to fire tests were carried out for the product as described below at Efectis Era Avrasya Test Laboratory on 16 of August 2022. Classification of reaction to fire has been carried out in accordance the standard:

EN 13501-1:2018

“PIR Filled Roof Panel – 80 mm”

Fire behaviour		Smoke production		Flaming droplets
B	-	s	2	, d 0

Flammability Classification*

Hardly inflammable

*Turkey's regulation on fire protection 2009, Appendix-2/Ç the table of flammability classification of construction materials in accordance with EN 13501-1

Placed on the market by: DAVUT PANEL ve SAC SAN. TİC. A.Ş.
Adana Hacı Sabancı O.S.B. Baklalı Yolu No:22 Sarıçam, Adana /
TURKEY

Manufactured by: DAVUT PANEL ve SAC SAN. TİC. A.Ş.
Adana Hacı Sabancı O.S.B. Baklalı Yolu No:22 Sarıçam, Adana /
TURKEY

e-signed

Ali BAYRAKTAR
Laboratory Manager
16.09.2022

This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report No: EEA-22-156.

